

**IOWA DEPARTMENT OF NATURAL RESOURCES
NPDS REPORTING SYSTEM - DISCHARGE MONITORING REPORT
FACILITY INFORMATION**

This form is valid 4/1/2015 to 3/31/2020

Facility Name: SIOUX CITY, CITY OF STP

Permit #: 9778001

Month/Year: 12 2017

Outfall #(s): 001 - DISCHARGE FROM AN ACTIVATED SLUDGE WASTEWATER TREATMENT PLANT.

Operator Name: Mark Simms


Certification #: 5129

Phone #: 712-279-6916

Lab Cert. #: 323

Comments: Seaboard Triumph Foods obtained approximately 4,500 gal of digested sludge on 12/20 to use as seed material for their anaerobic lagoons. Engineers requested a couple outfall samples be analyzed for a study. There is one extra pH result from 12/5 and there are two TRC samples one from 12/4 and 12/5. Influent flow from 12.28 and 12.29 likely inaccurate due to bar screen issues.

*Include Comments longer than 1000 characters in email

Signature:  5129 12/17

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for known violations.